


EMERSON, ARKANSAS

Water Tank Rehab


BID PROPOSAL

ITEM	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL PRICE
1	1	L.S.	Blast and Re-coat the full interior of the 50,000 gallon leg tank per plans and specifications for the lump sum price of	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.		
2	1	L.S.	Blast and Re-coat the full exterior of the 50,000 gallon leg tank per plans and specifications for the lump sum price of (Shall include removal of all cathodic protection and necessary repairs to steel)	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.		




BID PROPOSAL CONTINUED

ITEM	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL PRICE
3	1	L.S.	Provide and install 8" schedule 80 pvc riser pipe, including check valves, bracing, and appurtenances, on the EST, per plans and specs for the lump sum price of	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.		
4	1	L.S.	Provide and install overflow extension and concrete Splash pad on each of the 50,000 gallon tanks, per plans and specs for the unit price of	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.		




BID PROPOSAL CONTINUED

ITEM	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL PRICE
5	1	L.S.	Tighten all tensioning rods on the elevated Storage tank, per plans and specs for the unit price of _____ Dollars and Cents/L.S. _____	\$ _____	\$ _____
6	1	L.S.	Provide and install #24 stainless steel wire mesh on all vents and openings per plans and specs for the unit price of _____ Dollars and Cents/L.S. _____	\$ _____	\$ _____




BID PROPOSAL CONTINUED

ITEM	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL PRICE
7	1	L.S.	Provide and install new 32" diameter access hatch on the riser per plans and specs for the lump sum price of	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.		
8	1	L.S.	Furnish and Install new roof vent on the tank per plans and Specifications including all labor and materials for the unit price of	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.		




BID PROPOSAL CONTINUED

ITEM	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL PRICE
9	1	L.S.	Furnish and Install new 30"x30" flanged roof access hatch on the tank per plans and specifications for the unit price of	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.		
10	1	L.S.	Furnish and Install new water level indicator including new stainless steel cable, pulleys, float and target on the tank per plans and specifications for the unit price of	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.		




BID PROPOSAL CONTINUED

ITEM	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL PRICE
11	100	L.F.	Additional welding services, used at the direction of the engineer, per plans and specs for the unit price of _____ Dollars and Cents/L.F. _____	\$ _____	\$ _____
12	1	L.S.	Provide full containment for the 50,000 gallon EST for the duration of exterior blasting and painting for the lump sum price of _____ Dollars and Cents/L.S. _____	\$ _____	\$ _____




BID PROPOSAL CONTINUED

ITEM	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL PRICE
13	1	L.S.	Lead abatement and disposal per federal and state Regulations for the lump sum price of (To be used if lead test is positive)	\$ _____	\$ _____
			_____ Dollars and Cents/L.S.		
14	1	L.S.	Remove and dispose of all brush and limbs around the tank site and fence to allow for all work to be completed, per plans and specs for the lump sum price of	\$ _____	\$ _____
			_____ Dollars and Cents/L.S.		



BID PROPOSAL CONTINUED

ITEM	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL PRICE
15	1	L.S.	Furnish and install new, interior, bowl access ladder per plans and specs for the lump sum price of	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.		
16	1	L.S.	Provide and install 20 kW Emergency Generator with concrete pad, automatic transfer switch, manual transfer switch, emergency lighting, including all electrical conduit, wiring, and appurtenances as described in the plans and specs for the unit price of:	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.	_____	_____
			TOTAL BASE BID	\$ _____	



**BID PROPOSAL CONTINUED
DEDUCTIVE ALTERNATE #1**

ITEM	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL PRICE
17	1	L.S.	Deduct Item # 16 - Provide and install 20 kW Emergency Generator with concrete pad, automatic transfer switch, manual transfer switch, emergency lighting, including all electrical conduit, wiring, and appurtenances as described in the plans and specs for the unit price of:	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.	_____	_____
TOTAL DEDUCTIVE ALTERNATE #1				\$ _____	_____
TOTAL BASE BID LESS DEDUCTIVE ALTERNATE #1				\$ _____	_____

NOTES:

- 1) Miscellaneous items, directed work, connections, etc., not specifically listed but required to complete the proposed improvements to a complete and operational system shall be included in the Bid under the most appropriate Bid Item.
- 2) Any damage to the tank caused by proposed work shall be repaired per coating manufacturer's recommendations at no additional cost to the owner.
- 3) All fittings, valves and appurtenances must be lead free in accordance with public law 111-380.
- 4) Time required to complete work shall be 120 calendar days.
- 5) Contractor shall provide a lead test, conducted by a certified lab, of the interior and exterior coatings that are to be blasted, prior to beginning work.
- 6) Contractor is responsible for ensuring any and all applicable local, state and federal laws for abatement, containment and disposal of all lead contaminated materials are followed.