

CITY OF DELIGHT, ARKANSAS


TANKS REHAB

BID PROPOSAL

ITEM	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL PRICE
1	1	L.S.	Blast and Re-coat the full interior of the 26'd x 14' GST per plans and specifications for the lump sum price of	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.		
2	1	L.S.	Blast and Re-coat the full exterior of the 26'd x 14' GST per plans and specifications for the lump sum price of	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.		


BID PROPOSAL CONTINUED

ITEM	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL PRICE
3	1	L.S.	Furnish and install NSF approved caulk for the interior roof to rim angle connection, for the lump sum price of (for Standpipe and GST):	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.		
4	2	EA.	Furnish and install new sample tap per the plans and specifications for the unit price of (Standpipe and GST)	\$ _____	\$ _____
			_____ Dollars and _____ Cents/EA.		



BID PROPOSAL CONTINUED

ITEM	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL PRICE
5	1	L.S.	Provide full containment for the GST for the lump sum price of	_____	\$ _____
			_____ Dollars and Cents/L.S.		
6	3	EA.	Furnish and Install new 30"x30" flanged roof access hatch on the tank per plans and specifications for the unit price of	\$ _____	\$ _____
			_____ Dollars and Cents/EA.		




BID PROPOSAL CONTINUED

ITEM	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL PRICE
7	1	L.S.	Furnish and Install new #24 S.S. wire mesh on all vents and opening for the lump sum price of. (Include all 3 Tanks)	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.		
8	1	L.S.	Provide and install 8" schedule 80 pvc riser pipe, including check valves, bracing, and appurtenances per plans and specs for the lump sum price of (EST Only)	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.		


BID PROPOSAL CONTINUED

ITEM	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL PRICE
9	150	L.F.	Additional welding services, used at the direction of the Engineer, per plans and specs for the unit price of (Additional Welding completed without engineers prior approval will not be paid) (Welding necessary for other bid items shall be included in those line items)	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.F.		
10	3	EA	Furnish and Install new 32"D flanged side access hatch on the tank wall per plans and specifications for the unit price of	\$ _____	\$ _____
			_____ Dollars and _____ Cents/EA		




BID PROPOSAL CONTINUED

ITEM	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL PRICE
11	1	L.S.	Furnish and install all equipment, materials and labor necessary to modify the existing GST overflow per plans and specifications for the lump sum price of  _____ Dollars and _____ Cents/L.S.	\$ _____	\$ _____
12	1	L.S.	Furnish and install all equipment, materials and labor necessary to modify the existing 50,000 gallon EST overflow per plans and specifications for the lump sum price of  _____ Dollars and _____ Cents/L.S.	\$ _____	\$ _____




BID PROPOSAL CONTINUED

ITEM	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL PRICE
13	1	L.S.	Furnish and install all equipment, materials and labor necessary to modify the existing Standpipe overflow per plans and specifications for the lump sum price of  _____ Dollars and _____ Cents/L.S.	\$ _____	\$ _____
14	1	L.S.	Clean all dirt and foreign material from between the GST floor and concrete foundation and re-caulk for the lump sum price of.  _____ Dollars and _____ Cents/L.S.	\$ _____	\$ _____



BID PROPOSAL CONTINUED


ITEM	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL PRICE
15	1	L.S.	Clean all dirt and foreign material from between the Standpipe floor and concrete foundation and re-caulk for the lump sum price of.	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.		
16	1	L.S.	Furnish and Install new confined space entry signage on all manways per plans and specifications for the lump sum price of (Include All 3 Tanks)	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.		






BID PROPOSAL CONTINUED

ITEM	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL PRICE
17	2	EA.	Furnish and Install new roof vent per plans and specifications for the unit price of. (Standpipe and EST)	\$ _____	\$ _____
_____ Dollars and _____ Cents/EA.				_____	_____
18	1	L.S.	Blast and Re-coat the full interior of the 20' d x 78' Standpipe per plans and specifications for the lump sum price of	\$ _____	\$ _____
_____ Dollars and _____ Cents/L.S.				_____	_____




BID PROPOSAL CONTINUED

ITEM	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL PRICE
19	1	L.S.	Blast and Re-coat the full exterior of the 20'd x 78' Standpipe per plans and specifications for the lump sum price of	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.		=====
20	1	L.S.	Provide full containment for the standpipe for the lump sum price of	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.		




BID PROPOSAL CONTINUED

ITEM	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL PRICE
21	1	L.S.	Blast and Re-coat the full interior of the EST Standpipe per plans and specifications for the lump sum price of	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.		=====
22	1	L.S.	Blast and Re-coat the full exterior of the EST Standpipe per plans and specifications for the lump sum price of	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.		



BID PROPOSAL CONTINUED

ITEM	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL PRICE
23	1	L.S.	Provide full containment for the EST for the lump sum price of	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.		
24	1	L.S.	Provide Temporary water storage and pressure & pump communication at each site for use throughout construction per Plans and specifications for the lump sum price of	\$ _____	\$ _____
			_____ Dollars and _____ Cents/L.S.		
<b>TOTAL BASE BID</b>				\$ _____	



**DEDUCTIVE ALTERNATE #1**

1      1      L.S.    **Delete Item 18** - Blast and Re-coat the full interior of the 20'd x 78' Standpipe per plans and specifications for the lump sum price of

\$ \_\_\_\_\_ \$ \_\_\_\_\_

\_\_\_\_\_ Dollars and  
\_\_\_\_\_ Cents/LS. \_\_\_\_\_

**TOTAL DEDUCTIVE ALTERNATE** \$ \_\_\_\_\_

**TOTAL BASE LESS DEDUCTIVE ALTERNATE** \$ \_\_\_\_\_

- NOTES:
- 1) Miscellaneous items, directed work, connections, etc., not specifically listed but required to complete the proposed improvements to a complete and operational system shall be included in the Bid under the most appropriate Bid Item.
  - 2) Time required to complete base bid work shall be 225 calendar days.
  - 3) Contractor is solely responsible for following all applicable local, state and federal laws for lead abatement and disposal, as necessary.
  - 4.) Due to global raw material shortage in the coatings industry, it is in the best interest of the owner, engineer, and the job to purchase all coatings needed in one order. This will allow the project to continue and not slow due to unforeseen shortages.