

ADDENDUM NO. 1

TO: ALL PLAN HOLDERS
RE: City of McNeil, Arkansas-
Fun Park Improvements
DATE: August 9, 2024

The Plans, Specifications and Contract Documents for the above referenced project are hereby modified as follows:

Clarifications:


The roof material shall be 29-gauge metal.

Site prep for pavilion concrete slab shall include removal of organic material.

Slab finish grade is to match natural ground as close as possible.

ADDENDUM NO. 1 ISSUED BY:

A.L. FRANKS ENGINEERING



Anthony L. Franks, P.E.

