

ADDENDUM NO. 3

TO: ALL PLAN HOLDERS

RE: City of Bradley, Arkansas-Wastewater Improvements

ADDENDUM DATE: October 16, 2023

The Plans, Specifications and Contract Documents for the above referenced project are hereby modified as follows:

Bid Proposal Clarifications-

- *All directional bores longer than 28 L.F. shall use locking joint pipe.
- *All bore an encase PVC carrier pipe shall be locking joint.

ADDENDUM NO.3 ISSUED BY:

A.L. FRANKS ENGINEERING


Kiron Browning, P.E.
Project Manager

