

## ADDENDUM NO. 2

TO: ALL PLAN HOLDERS

RE: CITY OF DEQUEEN, ARKANSAS-GROUND STORAGE IMPROVEMENTS


ADDENDUM DATE: October 12, 2023

The Plans, Specifications and Contract Documents for the above referenced project are hereby modified as follows:

**Clarification-** Bid Item #12- Side Access hatch shall be 30" Diameter.  
Plan Sheet 4- Only 1 Interior ladder is to be replaced.

ADDENDUM NO.2 ISSUED BY:

A.L. FRANKS ENGINEERING

  
Kiron Browning, P.E.  
Project Manager

