

## ADDENDUM NO. 1

TO: ALL PLAN HOLDERS

RE: CITY OF GLENWOOD, ARKANSAS  
10" Water Main Replacement

DATE: June 15, 2022


The Plans, Specifications and Contract Documents for the above referenced project are hereby modified as follows:

### 1. Technical Specifications

- All HDPE water mains to be C906 DIPS DR-11, in lieu of DR-9, as stated in the specifications.
- All tie-ins and directional changes to made using MJ Adapters and Ductile Iron Fittings. Weld on fittings will not be approved.

ADDENDUM NO. 1 ISSUED BY:

A.L. FRANKS ENGINEERING

  
Kiron S. Browning, P.E.  
Project Engineer

