

ADDENDUM NO. 2

TO: ALL PLAN HOLDERS

RE: COVID Center – Lafayette County, Arkansas

ADDENDUM DATE: May 3, 2022

The Plans, Specifications and Contract Documents for the above referenced project are hereby modified as follows:

1. **Light Fixture Schedule: Remove all light fixtures “E” from plans and replace with fixture type “D”.**
2. **Exit signs to be placed above each D5 door and shall meet all requirements as required by the NFPA, Arkansas Building Code and Arkansas Fire Prevention Code for exit signs with emergency lighting. NEMA 4X rating not required as shown on Sheet 10 for interior placed signs.**
3. **Emergency lighting throughout building interior shall minimally meet NFPA, Arkansas Building Code and Arkansas Fire Prevention Code.**
4. **Sheet 10: Electrical contact shall be modified to Entergy Arkansas, LLC Contact: David Hinshaw 870-235-7153**
5. **Sheet 9: Exterior electrical receptacle shall be added near condenser to meet code requirements. Two additional receptacles shall be located in the 10x20 storage area, opposite of the two shown.**
6. **Sheet 10: Range shown on Panel is not needed. No range/oven included in building.**

PROJECT CLARIFICATION

1. Confirmed with Entergy that power to site is single phase. Power will not be moved underground along 4th Street, but Entergy will relocate pole shown in plans in parking lot to a new location out of conflict with site functionality and likely near the intersection of Maple and 4th streets. Contractor will be responsible for coordination of power, both temporary and permanent.
2. Geotechnical Report performed by E TTL attached for additional information.

ADDENDUM NO.2 ISSUED BY:

A.L. FRANKS ENGINEERING



Caleb Mudford, P.E.
Project Manager

ARKANSAS CERTIFICATE OF AUTHORIZATION NUMBER 1681

OKLAHOMA CERTIFICATE OF AUTHORIZATION NUMBER 5503

TEXAS CERTIFICATE OF REGISTRATION NUMBER F-10338



5-3-22