

CAMDEN WATER UTILITIES
CLEVELAND ROAD TANK CLEANING

CM-01-23

BID PROPOSAL


<u>ITEM</u>	<u>QTY/UNIT</u>	<u>DESCRIPTION</u>	<u>UNIT PRICE</u>	<u>TOTAL PRICE</u>
1.	1 L.S.	Blast and Re-coat the full interior of the 500,000 gallon Leg tank per plans and specifications for the lump sum price of _____ Dollars and _____ Cents/L.S.	\$ _____	\$ _____
2.	1 L.S.	Blast and Re-coat the full exterior of the 500,000 gallon Leg Tank and tighten the windage rods per plans and specifications for the lump sum price of _____ Dollars and _____ Cents/L.S.	\$ _____	\$ _____

BID PROPOSAL
(Cont'd)

<u>ITEM</u>	<u>QTY/UNIT</u>	<u>DESCRIPTION</u>	<u>PRICE</u>	<u>PRICE</u>
3.	1 L.S.	Provide full containment for the 500,000-gallon EST for the duration of exterior blasting and painting for the lump sum price of _____ Dollars and _____ Cents/L.S.	\$ _____	\$ _____
4.	1 L.S.	Furnish and Install new water level indicator, including New stainless steel cable, pulleys, float and target per plans and specifications for the lump sum price of _____ Dollars and _____ Cents/L.S.	\$ _____	\$ _____
5.	150 L.F.	Additional welding services, used at the direction of the Engineer, per plans and specs for the unit price of (Welding done prior to engineers approval will not be paid) _____ Dollars and _____ Cents/L.F.	\$ _____	\$ _____

BID PROPOSAL
(Cont'd)

<u>ITEM</u>	<u>QTY/UNIT</u>	<u>DESCRIPTION</u>	<u>PRICE</u>	<u>PRICE</u>
6.	1 L.S.	Furnish and Install a 10" sch 80 PVC riser pipe, 3-inlet Nozzles and 2-outlet check valves per plans and specifications for the lump sum price of _____ Dollars and _____ Cents/L.S.	\$ _____	\$ _____
7.	1 L.S.	Furnish and install confined space entry signs on all Access hatches, per plans and specs for the lump sum price of _____ Dollars and _____ Cents/L.S.	\$ _____	\$ _____
TOTAL BASE BID			\$ _____	



- NOTES:**
- 1) Miscellaneous items, directed work, connections, etc., not specifically listed but required to complete the proposed improvements to a complete and operational system shall be included in the Bid under the most appropriate Bid Item.
 - 2) Any damage to the tank or existing coating (interior and exterior) caused by proposed work shall be repaired per coating manufacturer's recommendations at no additional cost to the owner. Coating repair specification is included.
 - 3) All fittings, valves and appurtenances must be lead free in accordance with public law 111-380
 - 4) Time required to complete work shall be 75 calendar days. Documented manufacturers delays, of specified materials, may be taken into consideration for time extensions.
 - 5) Contractor is responsible for ensuring any and all applicable local, state and federal laws for abatement, containment and disposal of all lead contaminated materials are followed.
 - 6) Bid Item #5, additional welding, is to be used in the event there is welding necessary outside the scope of the other bid items. Welding that is necessary to complete the other bid items shall be included in the price of the corresponding bid items.

